



CERTIFICATE

Issued to:
Applicant:
LINKK Busways Technology Sdn Bhd
Wisma LFE, Lot 43117, Off Jalan Balakong,
43300 Balakong, Seri Kembangan, Selangor
Darul Ehsan, Malaysia

Manufacturer/Licensee:
LINKK Busway Systems (M) Sdn Bhd
Wisma LFE, Lot 43117, Off Jalan Balakong,
43300 Balakong, Seri Kembangan, Selangor
Darul Ehsan, Malaysia

Product(s) : Low-voltage busbar trunking system (copper bar)
Trade name(s) : MEGADUCT
Type(s)/model(s) : MEGADUCT1000A, MEGADUCT1250A, MEGADUCT1600A, MEGADUCT2500A,
MEGADUCT5000A

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
- a type test according to the standard EN 61439-6:2012; IEC 61439-6:2012;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2166000

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 11 March 2014 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3306139.02

DEKRA Certification B.V.

drs. G.J. Zoetbrood
Managing Director

H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL

